



33	Max. MW Demand felt		4589	4631	4699	4875	4916	5435	
----	---------------------	--	------	------	------	------	------	------	--

## DISCOM DATA DATED : 21-09-09

Name of Operation Zone	Weather	RUNNING HOURS				
		Rural Domestic	Agriculture T/W	Industry	Urban Domestic	
Delhi Zone	Clear	14:07	8:00	18:46	22:32	
Hissar Zone	Clear	14:07	8:00	19:22	22:15	
DHBVN Average		14:07	8:00	19:04	22:24	
Running Hours as per PRM		14:00	8:00	19:00	21:00	
Panchkula Zone	Clear	14:00	8:10	14:14	18:45	
Rohtak Zone	Clear	14:33	9:34	14:15	18:14	
UHBVN Average		14:16	8:52	14:14	18:29	
Running Hours as per PRM		14:00	8:00	16:00	21:00	
Power Cuts / Major Breakdown in Hrs., if any						
DHBVN		NIL	NIL	NIL	NIL	
UHBVN		NIL	NIL	1.46	2.31	

Name of Plant	Capacity (MW)	Generation (in MW) on last Midnight.							REASON
		15-Sep	16-Sep	17-Sep	18-Sep	19-Sep	20-Sep	21-Sep	
PTPS-I	110	0	101	101	103	111	111	111	
PTPS-II	110	84	77	88	80	0	0	0	Tripped at 16:00 Hrs (19.09.09) due to fire in turbine side.
PTPS-III	110	62	75	70	70	72	77	73	
PTPS-IV	110	0	20	70	70	79	79	81	
PTPS-V	210	205	205	205	180	190	210	210	
PTPS-VI	210	0	198	216	210	210	208	190	
PTPS-VII	250	0	250	254	258	255	258	255	
PTPS-VIII	250	230	257	260	0	0	0	0	Tripped at 19:20 Hrs. (18.09.09) due to fire in switch yard.
YTPP-I	300	299	304	303	314	304	305	302	
YTPP-II	300	201	219	0	0	0	0	235	Synchronized at 12:28 Hrs.(21.09.09).
FTPS-I	55	0	0	0	0	0	0	0	Tripped at 21:25 Hrs.(04.09.09) due to furnace pressure high

<b>FIPS-III</b>	55	32	35	40	39	38	38	38	
<b>Total</b>	<b>2070</b>	<b>1113</b>	<b>1741</b>	<b>1607</b>	<b>1324</b>	<b>1259</b>	<b>1286</b>	<b>1495</b>	
<b>Data is for monitoring purposes only &amp; as per fig. supplied by PC/HVPN</b>									